From: O'Connor, Mike
Sent: Tuesday, April 12, 2016 4:12 PM
To: 'Jeff Lightheart'
Subject: FW: Corvallis Burgerville

Jeff,
I received your revision package for Burgerville today. It is being routed under the first permit BLD15-00764 since the changes are associated with the main building.
Separately, your response to the Patio permit BLD16-00131 is sufficient for my needs to approve it (after Lisa has a look), but the Fire Feature and gas line revision will still have to come in as a revision to the Patio permit. Please review the bulleted outline below for that process.

Respectfully,

Michael T. O'Connor
Project Coordinator
Phone: (541) 766-6538
mike.oconnor@corvallisoregon.gov

From: O'Connor, Mike
Sent: Thursday, April 07, 2016 8:23 AM
To: 'Jeff Lightheart'
Subject: Corvallis Burgerville

Jeff,
Our Building Inspector for your project approached me this morning asking about the 'Fire Feature' on the patio. To which I replied "huh?" The contractor was pressing him to approve a 2 pound gas line run out to where the central bench seat is. All this to say, 1) do you know about this change, 2) if so, please submit revised drawing sheets showing this change, 3) revise the Mechanical plans to indicate the piping sizes – lengths – and appliance demand, 4) provide the Manufactures Listing for the fire feature.

Respectfully,

Michael T. O'Connor
Project Coordinator
Phone: (541) 766-6538
mike.oconnor@corvallisoregon.gov