From: Franklin, Lisa
Sent: Monday, February 01, 2016 4:51 PM
To: 'Jeff Lightheart'
Cc: O'Connor, Mike; Russell, Kevin
Subject: RE: Burgerville Corvallis

Jeff…

If you submit plans showing flood-proofing and compliance with current floodplain design standards, then we may issue your permit with the condition that a final elevation certificate and flood-proofing certification are required prior to any occupancy being granted. If you obtain a LOMA from FEMA, then we can accept that and remove the certification requirement.

Please let me know if you have any questions.

Lisa M. Franklin, EI, CFM
City of Corvallis Development Services
Direct line: 541.766.6542
www.corvallispermits.com

From: jefflightheart@gmail.com [mailto:jefflightheart@gmail.com] **On Behalf Of** Jeff Lightheart
Sent: Monday, February 01, 2016 10:36 AM
To: Franklin, Lisa
Cc: O'Connor, Mike
Subject: Burgerville Corvallis

Lisa:

Update on the floodplain issue and am using your e-mail of 12-16-15 to show our "steps" in the process:

We had the property surveyed by Olson Engineering (1-14-16) and their results were that the existing finish floor is at 225.08 (NGVD 29) and that the lowest adjacent grade is 224.32' (NGVD 29) - so we are below the 225.5
(NGVD 29).

Since the survey work showed that the LAG is lower than 224.5, Olson Engineering has attempted to find existing grade information to use a different method but was unable to find sufficient data so is planning to do additional field work to prepare cross sections to support a petition to FEMA to remove the building from the floodplain. We know the building to the north has been removed based on an elevation of 225.15 (NGVD 29). Work on the FEMA petition is on-going.

Finally, we have prepared building up-grade drawings and certifications to show compliance with flood=proofing to 1-ft above BFE per LDC 4.5.100.08 & LDC 4.5.110.

Since the FEMA petition could take 45-60 days for a response - our question is - if we submitted the flood-proofing up-grades and certification, could you "condition" a permit issuance that would allow Burgerville to start construction and we would install the flood-proofing up-grades if the FEMA request is not approved.

We are available this week to come down and discuss if you think that would help. Thanks

Jeff

--

Jeffrey A. Lightheart, A.I.A.
LLB Architecture
Vancouver, WA

Disclaimer: This e-mail message may be a public record of the City of Corvallis. The contents may be subject to public disclosure under Oregon Public Records Law and subject to the State of Oregon Records Retention Schedules. (OAR:166.200.0200-405)